


StoTherm® - 1177-LM-150

Large Missile Hurricane Impact Resistant System

Miami-Dade County NOA # 16-0418.07 Expires: 08/11/2021

Detail No.: 10H.14

Date: April 2017



- 1 6", 16 ga. Steel Studs at 16-inches on-center.
- 2 5/8-inch fiberglass faced ASTM C-1177 sheathing
- 3 Sto Armor Mat XX Embedded in Sto Primer/Adhesive-B
- 4 Sto Gold Coat®
- 5 Sto Primer/Adhesive-B
- 6 Miami-Dade County Listed EPS, 1.0 pcf, Minimum 1-inch Thick
- 7 Sto Mesh Embedded in Sto Primer/Adhesive-B
- 8 Sto Finish
- 9 No. 6 x 1-1/4" Screws Spaced at 6 inches On-Center Along Studs in Field and Perimeter.

HVHZ
Design Pressure:
 ± 150 p.s.f.

Property of Sto Corp. All Rights Reserved.

IMPORTANT: Components not identified as Sto are furnished by other manufacturers and are not necessarily installed by trades who install the Sto products. Refer to project specific contract documents.

Notes:

1. Comply with written requirements presented in official Notice of Acceptance available at www.stocorp.com and www.miamidade.gov.
2. Materials deemed equivalent or better may be substituted based on analysis by a qualified engineer and/or at the discretion of the local code official in locations outside of the High Velocity Hurricane Zone (Dade and Broward Counties).
3. Refer to Sto specifications and product bulletins for detailed information on mixing and application of products.

www.stocorp.com

ATTENTION

Sto products are intended for use by qualified professional contractors, not consumers, as a component of a larger construction assembly as specified by a qualified design professional, general contractor or builder. They should be installed in accordance with those specifications and Sto's instructions. Sto Corp. disclaims all, and assumes no, liability for on-site inspections, for its products applied improperly, or by unqualified persons or entities, or as part of an improperly designed or constructed building, for the nonperformance of adjacent building components or assemblies, or for other construction activities beyond Sto's control. Improper use of Sto products or use as part of an improperly designed or constructed larger assembly or building may result in serious damage to Sto products, and to the structure of the building or its components.

STO CORP. DISCLAIMS ALL WARRANTIES EXPRESSED OR IMPLIED EXCEPT FOR EXPLICIT LIMITED WRITTEN WARRANTIES ISSUED TO AND ACCEPTED BY BUILDING OWNERS IN ACCORDANCE WITH STO'S WARRANTY PROGRAMS WHICH ARE SUBJECT TO CHANGE FROM TIME TO TIME. For the fullest, most current information on proper application, clean-up, mixing and other specifications and warranties, cautions and disclaimers, please refer to the Sto Corp. website, www.stocorp.com.

